




2009-12-25



5011693600-RPD0



RTU-PD01 INSTRUCTION SHEET

安裝說明 安装说明

- ▲ PROFIBUS DP Slave Communication Module
- ▲ PROFIBUS DP 從站通訊模組
- ▲ PROFIBUS DP 从站通讯模块



www.delta.com.tw/industrialautomation

DVP-1055830-01

Warning ENGLISH

- This instruction sheet only provides introductory information on electrical specification, functions, installation and wiring.
- RTU-PD01 is an OPEN-TYPE device and therefore should be installed in an enclosure free of airborne dust humidity, electric shock and vibration. The enclosure should prevent non-maintenance staff from operating the device (e.g. key or specific tools are required to open the enclosure) in case danger and damage on the device may occur.
- Switch off the power before wiring. Check all the wiring again before switching on the power. DO NOT touch any terminal when the power is switched on.
- DO NOT touch the internal circuit in one minute after the power is switched off.
- DO NOT connect input AC power supply to any of the I/O terminals; otherwise serious damage may occur.
- Make sure the ground terminal is correctly grounded in order to prevent electromagnetic interference.


● Introduction

Thank you for choosing Delta RTU-PD01 PROFIBUS DP Slave Communication Module. The power is supplied by the DC 24V power supply. The right side of RTU-PD01 is connectable with DVP-Slim series digital and analog I/O modules, and the RS-485 COM port is connectable to standard Modbus slave station.

■ Features

1. Supports PROFIBUS DP cyclic data transmission.
2. Auto-detects baud rates; supports Max.12Mbps.
3. Self-diagnosis.
4. Able to connect to max. 8 DVP-Slim type special I/O modules and 32 digital I/O modules (max. 256 points) at right side.
5. The RS-485 COM port is able to connect to max. 16 standard Modbus slave stations.
6. Supports max. 100 bytes of data input and 100 bytes of data output.

■ Product Profile & Outline



● Specifications

■ PROFIBUS DP Port

Interface	DB9 connector
Transmission method	High-speed RS-485
Transmission cable	Shielded twisted pair cable
Electrical isolation	500VDC

■ Communication

Message type	Cyclic data exchange
Module name	RTU-PD01
GSD document	DELA0989.GSD
Product ID	0989(HEX)
Serial transmission speed supported (auto-detection)	9.6kbps; 19.2kbps; 93.7kbps; 187.5kbps; 500kbps; 1.5Mbps; 3Mbps; 6Mbps; 12Mbps (bits per second)

■ Electrical Specification

Power supply voltage	24VDC
Insulation voltage	500VDC
Power consumption	2.5W
Weight	90g

■ Environment

Noise immunity	ESD(IEC 61131-2;IEC 61000-4-2): 8kV Air Discharge EFT(IEC 61131-2;IEC 61000-4-4): Power Line:±2kV;Digital Input:±2kV Communication I/O: ±2kV Conducted Susceptibility Test (EN61000-4-6, IEC 61131-2 9.10): 150kHz ~ 80MHz, 10V/m RS (IEC 61131-2, IEC 61000-4-3): 26MHz ~ 10Hz, 10V/m
Storage/operation	Operation: 0°C ~ 50°C (temperature), 50 ~ 90% (humidity), pollution degree 2 Storage: -25°C ~ 70°C (temperature), 5 ~ 95% (humidity)
Shock/vibration immunity	International standards: IEC 61131-2;IEC 68-2-6 (TEST Fc) IEC 61131-28 & IEC 68-2-27 (TEST Ea)

● Components

■ RUN/STOP Switch

Status	Description
RUN ⇨ STOP	1. Special I/O module switches from RUN to STOP 2. All I/O points on digital output module turn OFF. 3. Modbus function switch 4. RUN LED goes off.
	1. RTU-PD01 re-detected the number of digital I/O points and special I/O modules. 2. Special I/O module switches from STOP to RUN. 3. Enable digital I/O modules. 4. Enable Modbus function. 5. RUN LED goes on.
STOP ⇨ RUN	

■ Address Setup Switch

The two rotary address setup switches, x16¹ and x16², set up the node address of RTU-PD01 on PROFIBUS DP network in hex form. The range for rotation is 0 ~ F (see below more details).

Address	Definition
H1 ~ H7D	Valid PROFIBUS address
H0 or H7E ~ HFF	Invalid PROFIBUS address. NET LED will flash in red color if the node address falls within this range.

Example: If you need to set the node address of RTU-PD01 to 26 (decimal), simply switch x16¹ switch to "1" and x16² to "A". 26 (decimal) = 1A (hex) = 1x16¹ + Ax16².

Note:

- Please switch off the power supply before setting up the node address of RTU-PD01. Re-power the module after the setup is completed.
- Changing the value on the switch during the operation of RTU-PD01 is invalid.
- Use slot type screwdriver to set up the switch. Be careful not to scratch the module.


● Installation

■ Definition of PROFIBUS DP Port

PIN	PIN name	Definition
1	-	Not defined
2	-	Not defined
3	RxD/Txd-P	Sending/receiving data P(B)
4	-	Not defined
5	DGND	Data reference potential
6	VP	Power voltage - positive
7	-	Not defined
8	RxD/Txd-N	Sending/receiving data N(A)
9	-	Not defined


■ Connecting to PROFIBUS DP Port

Insert the PROFIBUS DP bus connector into the PROFIBUS DP port on RTU-PD01. Screw it tight to ensure RTU-PD01 and the PROFIBUS DP are properly connected.



■ Installing RTU-PD01 & I/O Module on DIN Rail

1. Use 35mm DIN rail.
2. Open the DIN rail clips on RTU-PD01 and I/O module. Insert RTU-PD01 and I/O module on the DIN rail.
3. Clip up the DIN rail clips on RTU-PD01 and I/O module to fix them on the DIN rail.



● LED Indicator & Trouble-shooting

There are 5 LED indicators on RTU-PD01: POWER, NET, RS-485, RUN and ALARM.

■ POWER LED

POWER LED displays whether the power supply on RTU-PD01 is working normally.

LED status	Indication	How to correct
Green light on	Normal	--
Off	No power supply	Check if the power supply is normal.

■ NET LED

NET LED displays whether the communication between RTU-PD01 and PROFIBUS DP master is working normally.

LED status	Indication	How to correct
Green light on	Normal	--
Red light on	RTU-PD01 is not connected to the master.	<ol style="list-style-type: none"> 1. Check if RTU-PD01 is connected to PROFIBUS DP bus. 2. Check if the communication cable between RTU-PD01 and PROFIBUS DP master is in normal condition. 3. Check if the actual address of RTU-PD01 is consistent with the one set in the master configuration software.
Red light flashes	RTU-PD01 setting or configuration error.	<ol style="list-style-type: none"> 1. Check if the PROFIBUS address of RTU-PD01 is between 1 and 125 (decimal). 2. Check if the I/O modules actually connected to RTU-PD01 and their order are consistent with the software configuration.

■ RS-485 LED

RS-485 LED displays whether the RS-485 communication between RTU-PD01 and Modbus device connected is working normally.

LED status	Indication	How to correct
Green light on	Normal	--
Green light flashes	The Modbus function has not been enabled, or no Modbus slave is configured	--
Red light on	All Modbus slaves are off-line.	Check if the RS-485 cable is working normally, or the communication format is correct.
Red light flashes	The RS-485 communication with part of the Modbus devices connected is abnormal.	Check if the part of the RS-485 devices connected have not responded or responded incorrectly.

■ RUN LED

RUN LED displays whether RTU-PD01 is operating or in stop status.

RUN status	Indication
Green light on	RTU-PD01 is operating.
Off	RTU-PD01 is in stop status.

■ ALARM LED

ALARM LED displays whether the right-side special I/O module is working normally and the power supply is sufficient.

LED status	Indication	How to correct
Off	Normal	--
Red light on	DC24V power supply is insufficient	Check if the power supply is overload
Red light slowly flashes (on 0.5s and off 0.5s)	Error in special I/O module	Please refer to the explanations on error registers for special I/O module in "DVP-PLC Application Manual – Special Modules".
Red light fast flashes (on 0.3s and off 0.3s)	Special I/O module is off-line	<ol style="list-style-type: none"> 1. Check if the power supply on special I/O module is normal. 2. Check if the connection between RTU-PD01 and special module is working normally.

■ 電氣規格

電源額定壓	24VDC
絕緣電壓	500VDC
消耗電力	2.5W
重量	90g
備註	RS-485 速率支援 12Mbps

■ 環境規格

操作 / 儲存環境	操作: 0°C ~ 50°C (溫度); 50 ~ 90% (濕度); 污染等級 2
衝擊 / 震動	衝擊標準規範: IEC 61131-2, IEC 68-2-6 (TEST Fc)/IEC 61131-28 (TEST Ea)
耐振動	衝擊標準規範: IEC 61131-2, IEC 68-2-7 (TEST Ea)

● 注意事項

- ✓ 此安裝手冊僅提供電氣規格、一般規格、安裝及配線等說明。
- ✓ 本機為開放型 (OPEN TYPE) 機殼，因此使用者使用本機時，必須將之安置於異於防塵、防潮及免於電擊或意外擊穿之處。
- ✓ 配線時請務必關閉電源，且於上電前再次確認電源配線，並請勿在上電前觸摸任何端子。
- ✓ 請勿將電源線直接連接至輸入/輸出端子，否則可能造成嚴重損壞。
- ✓ 本體上的接地端子 請正確的接地，以提高產品抗干擾能力。


● 產品簡介

- 感謝您使用台達 RTU-PD01 諾通路網通訊模組。RTU-PD01 定義為 PROFIBUS DP 從站通訊模組，由直流 24V 電源供電。RTU-PD01 右側可連接 Slim 系列特殊輸入/輸出模組及數位輸入/輸出模組，其 RS-485 通訊埠可連接標準的 Modbus 從站。

● 功能特色

1. 支持 PROFIBUS DP 週期性資料傳輸
2. 自動偵測通訊速率，最高通訊速率支援 12Mbps
3. 自診斷功能
4. RTU-PD01 右側最多可接 8 台 Slim 系列特殊輸入/輸出模組，及 32 台數位輸入/輸出模組（數位輸入和輸出點數各 256 點）
5. RTU-PD01 的 RS-485 通訊埠最多可接 16 台標準的 Modbus 從站
6. I/O 資料最大支援 100 個位元組輸出和 100 個位元組輸入

● 產品外觀



● 各部份元件介紹

■ RUN/STOP 開關

狀態	說明
RUN 按至 STOP	1. 特殊輸入 / 輸出模組由 RUN 切換到 STOP 狀態 2. 數位輸入模組的丫點全部變爲 OFF 狀態

